

NATURALTECH PTY LTD (WoodEvo™ Premium Deck) TEST REPORT

SCOPE OF WORK

WoodEvo™ Premium Wood Composite Deck

REPORT NUMBER

191121014SHF-001

TEST DATE(S)

2019-11-21 - 2019-12-04

ISSUE DATE

2019-12-04

PAGES


5

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2019)

© 2019 INTERTEK

Intertek Testing Services Shenzhen Ltd. Shanghai Fengxian Branch



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

Test Report

Issue Date: 2019-12-04 Intertek Report No. 191121014SHF-001
Applicant: NATURALTECH PTY LTD (WoodEvo™ Premium Deck)
Address: 5/21 Howleys Road, Notting Hill VIC 3168 AUSTRALIA
Attn: Yuki Liu
Test Type : Performance test, samples provided by the applicant.

Product Information

Product Name	WoodEvo™ Premium Wood Composite Deck	Brand	WoodEvo™
Sample Description	Good Condition	Sample Amount	8 pieces
		Received Date	2019-11-04
Sample ID	Model	Specification	
S191121014SHF.001	WoodGrain	138*22mm*5400mm	

Test Methods And Standards

Test Standard	AS 4586:2013 Appendix D
Specification Standard	/
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Report Authorized



 Name: Flora Fan Name: Milo Liu
 Title: Reviewer Title: Project Engineer

Test Report

Issue Date: 2019-12-04

Intertek Report No. 191121014SHF-001

Test Items, Method and Results:

Test Item: Oil-wet inclining platform test

Test Method: AS 4586:2013 Appendix D

Conditioning: Condition the test specimens at $(23 \pm 2)^{\circ}\text{C}$ and $(50 \pm 5)\%$ relative humidity for 48 hours

Test Item	Test Method	Test Result
Oil-wet inclining platform test	AS 4586:2013 Appendix D	Angle: 20.9°
		Classification: R11

Note:

1. Test item was subcontracted on accreditation by CNAS L1401.

Classification of Pedestrian surface materials according to the oil-wet inclining platform test

Classification	Angle, degrees
No Classification	$X < 6$
R9	$6 \leq X < 10$
R10	$10 \leq X < 19$
R11	$19 \leq X < 27$
R12	$27 \leq X < 35$
R13	$X \geq 35$

Test Report

Issue Date: 2019-12-04

Intertek Report No. 191121014SHF-001

Appendix A: Sample Received Photo



Revision:

NO.	Date	Changes	Author	Reviewer
191121014SHF-001	2019-12-04	First issue	Milo Liu	Flora Fan